

Certificate of Compliance

Certificate: 1084351

Master Contract: 204919

Project: 1428 288

Date Issued: March 26, 2004

Issued to: CABLOFIL INC.
8319 State Route 44
Mascoutah, IL 62258
USAA

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US'



Issued by: Jean-Claude Chow, Eng.

Authorized by: Alain Ste-Marie
Operations Manager

PRODUCTS

CLASS 4681 01 - WIREWAYS AND BUSWAYS - Cabletroughs

CLASS 4681 81 - WIREWAYS AND BUSWAYS - Cabletroughs - Certified to US Standards

Cable Tray Systems, Steel Wire Type, **CF SERIES**, Cat. Nos: **CF54/XY** (50 mm (2 in) deep), **CF105/XY** (100 mm (4 in) deep), **CF150/XY** (150 mm (6 in) deep); 50 to 600 mm (2 to 24 in) wide max, with the following Load/span classification:

Cat. No.	Depth (Nominal) mm	Width (Nominal) mm	DESIGN LOAD (kg/m) at varying support spacings (Span lengths)					
			SPAN LENGTH (meters)					
			1.5 m	1.8 m	2.1 m	2.4 m	2.7 m	3.0 m
CF54/50	50	50	LOAD RATINGS AVAILABLE UPON REQUEST					
CF54/100	50	100						
CF54/150	50	150						
CF54/200	50	200						
CF54/300	50	300						
CF54/400	50	400						
CF54/450	50	450						
CF54/500	50	500						
CF54/600	50	600						



Certificate: 1084351

Master Contract: 204919

Project: 1428 288

Date: March 26, 2004

Continued:

Cat. No.	Depth (Nominal) mm	Width (Nominal) mm	DESIGN LOAD (kg/m) at varying support spacings (Span lengths)					
			SPAN LENGTH (meters)					
			1.5 m	1.8 m	2.1 m	2.4 m	2.7 m	3.0 m
CF105/100	100	100	Load	Rating	Available	Upon	Request	
CF105/150	100	150						
CF105/200	100	200						
CF105/300	100	300						
CF105/400	100	400						
CF105/450	100	450						
CF105/500	100	500						
CF105/600	100	600						
CF150/150	150	150						
CF150/200	150	200						
CF150/250	150	250						
CF150/300	150	300						
CF150/400	150	400						
CF150/450	150	450						
CF150/500	150	500						
CF150/600	150	600						

Cat. No.	Depth (Nominal) inches	Width (Nominal) inches	DESIGN LOAD (lb/ft at varying support spacings (Span lengths)					
			SPAN LENGTH (feet)					
			5 ft	6 ft	7 ft	8 ft	9 ft	10 ft
CF54/50	2	2	Load	Rating	Available	Upon	Request	
CF54/100	2	4						
CF54/150	2	6						
CF54/200	2	8						
CF54/300	2	12						
CF54/400	2	16						
CF54/450	2	18						
CF54/500	2	20						
CF54/600	2	24						
CF105/100	4	4						
CF105/150	4	6						
CF105/200	4	8						
CF105/300	4	12						
CF105/400	4	16						
CF105/450	4	18						
CF105/500	4	20						
CF105/600	4	24						



Certificate: 1084351

Master Contract: 204919

Project: 1428 288

Date: March 26, 2004

Continued :

Cat. No.	Depth (Nominal) inches	Width (Nominal) inches	DESIGN LOAD (lb/ft at varying support spacings (Span lengths))					
			SPAN LENGTH (feet)					
			5 ft	6 ft	7 ft	8 ft	9 ft	10 ft
CF150/150	6	6	Load	Ratings	Available	Upon	Request	
CF150/200	6	8						
CF150/250	6	10						
CF150/300	6	12						
CF150/400	6	16						
CF150/450	6	18						
CF150/500	6	20						
CF150/600	6	24						

NOTES:

1) XY means that suffixes numbers and letters (or combination of) are added to the above catalogue numbers to denote width (50 to 600 mm), anti-corrosive treatment (EZ = Electro zinc, GC = Hot Dip galvanized, IN = Stainless Steel), colours etc.
 EXAMPLE: CF54/300 EZ = CF Series, 50 mm (2 inches) deep, 300 mm (12 inches) wide treated by Electro zinc anti-corrosive method.

2) To be used in accordance with the rules of the Canadian Electrical Code (CEC) Part I and the National Electrical Code (NEC) Section 392, and installed in accordance with the manufacturer's recommendations.

APPLICABLE REQUIREMENTS

- CSA Standard C22.2 No. 126.1-02 - Metal Cable Tray Systems (Bi-National Std, with NEMA VE 1-2002)
- NFPA 70 - National Electrical Code (NEC) 2002 Edition